

T/LL174 Liquid Level Installation Instruction

Mechanical

The T/LL174 is usually mounted vertically but may be mounted at any angle above the horizontal providing it spans the depth of the tank.

The thread should be tightened to a torque not exceeding 22 Nm (16.2 lb-ft).

Maximum Ratings

Supply Voltage: 9-30VDC.

Supply Current: 50 mA @ 15VDC incl. output load. Voltage Source: 1-5 V, 100 k Ω min. output load.

Pressure: 1 bar (14.5 psi). -20°C to +85°C. Operating Temp:


Other Parameters

Sealing: IP67.

Compatible Liquids: Diesel, biodiesel, kerosene, petrol, ethanol, water.

Accuracy: ±2% of depth @ -20°C to +80°C. Weight: 150g (500mm long sensor)

Electrical Connections:




A = Ground

B = 1-5 VDC

C = Not connected

D = V +

Matting Connector: Rochester Sensors C/K1 (4-way Delphi Packard Metri – Pack 150 series). To fit 8.0-1.0mm² conductor, Ø1.6-2.15 mm sleeve.



details are correct at the time of printing, Rochester Sensors UK Limited reserves the right to make material changes, and or technical changes without notification.

